

Certificate of Compliance

Certificate Number 5/29/07 FILE EX15246
Report Reference EX15246 2007-04-17
Issue Date 2007 May 29

Page 1 of 1



**Underwriters
Laboratories Inc.®**

Issued to:

Viking Plastics LLC

202 Industrial Dr.
Huntsville, AL 35811

*This is to certify that
representative samples of*

(CPVC) Sprinkler Pipe and Fittings:

BlazeMaster® Chlorinated Polyvinyl Chloride (CPVC) pipe (SDR 13.5) in sizes 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2 and 3 inch with a rated pressure of 175 psig.

*Have been investigated by Underwriters Laboratories Inc.® in accordance
with the Standard(s) indicated on this Certificate.*


Standard(s) for Safety:

The basic standards used to investigate products in this category are ANSI/UL 1821, "Thermoplastic Sprinkler Pipe and Fittings for Fire Protection Service," and ANSI/UL 1887, "Fire Test of Plastic Sprinkler Pipe for Flame and Smoke Characteristics."

Additional Information:

The products covered by this Report are for use in accordance with the National Fire Protection Association Standards for Installation of Sprinkler Systems, NFPA 13; Installation of Sprinkler Systems in Residential Occupancies Up to and Including Four Stories in Height, NFPA 13R; Installation of Sprinkler Systems in One- and Two-Family Dwellings and Manufactured Homes, NFPA 13D; and the manufacturer's installation & design manual dated January 10, 2007.

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product

Issued by:

Don Ross/ *Don Ross* DRW
Underwriters Laboratories Inc.

Reviewed by:

Daniel Weaver/ *Daniel A. Weaver*
Underwriters Laboratories Inc.